



RAJKOT MUNICIPAL CORPORATION

સ્વચ્છ
સર્વેક્ષણ
લીગ 2020



Fire And Emergency Services

Dr. Ambedkar Bhavan, Dhebar Road, Rajkot – 360 001. Phone. No.2227222.

RMC/RFES/F.No.B189/Renew School Building/NOC/ 168/2021. Date. 17.6.2021.
FSCA/0/RJ/2021/00005481.

::: RENEW FIRE NO OBJECTION CERTIFICATE :::
Ref. No.1.R.M.C.F.B.E.NO.NOC.117, DATE:-26.05.2021.
2.RMC/FES/ OLD NOC NO.86, Date:-29.05.2019.

This to Renew School Fire No Objection Certificate That With Reference to Above Application of Plan For Owner Krishnakant Girdharlal Dholakiya, Gyanganga Education Society, " SHREE K. G. DHOLAKIYA SCHOOL ", Type of Building :-Frame Structure, Use of Building :-Education Building, Building Floor :- Cellar + G.F + 1st To 4th Floor + Stair Room, Height of Building:-18.96 Mt. Location:-B/h Balaji Hall, 150ft Ring Road, Rajkot, T.P.S.No.7 (Nanamava), F.P.No.4 To 13/A, Area Table:- Total Plot Area :-6609.96 sq.mt, F.S.I. Used:-9913.08/6609.96 = 1.499 < 1.50. The School Building Site Was Inspected by RMC Fire Brigade Fire Station Officers and The Documents Submitted Were Checked and Found Correct on Date:-27.05.2021.

• During inspection of the said premises following system were found adequate and in working condition.

- (1) Fire Hydrant System with Hose Box, Hose Pipe with Nozzle & Hose Reel in Working Condition each floor.
- (2) ABC Fire Extinguishers 6 kg Capacity each floor.
- (3) CO2 Fire Extinguishers 4.5 kg Capacity each floor.
- (4) Fire Pump ON/OFF Switch each floor.
- (5) Emergency Fire Alarm System each floor.
- (6) Cellar Area Fire Sprinkler System.
- (7) Two way fire Service inlet 2 way.

• You are hereby advised to maintain the above system in good working condition.

- (1) The Fire Fighting System to be Maintain perfect working condition all the time.
- (2) In Case of Emergency Fire Safety System must be operated by your trained person immediately.
- (3) The Fire Department of RMC will not be responsible for any loss of life & property Due to Fire/Emergency incident of your premises.
- (4) Electric Wiring must be proper and that Not be Loose and Taped in Building Area.
- (5) Fire Water Tank for fire fighting in Above area.
- (6) Trained man power shall be available for Fire fighting premises round the clock.
- (7) Our fire Certificate is limited to Fire Fighting System available in your premises Only.
- (8) Any other instructions given by fire Department from time to time about fire Safety of the premises to be followed.
- (9) The duration of the Fire N.O.C. is valid up to One Year from the Date of Inspection.

Dy. Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation



Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation
(IN) PRINCIPAL
SHREE K. G. DHOLAKIYA SCHOOL,
RAJKOT.